

DEPARTMENT OF HAWAIIAN HOME LANDS
STATE OF HAWAII

MARCH 22, 2017

ADDENDUM NO. 2

TO

PLANS, BID FORM, SPECIFICATIONS, CONTRACT AND BOND

FOR

KANAKALOLOA CEMETERY IMPROVEMENTS


HOOLEHUA, MOLOKAI

IFB-17-HHL-012

NOTICE TO ALL PROSPECTIVE BIDDERS

This addendum is hereby made a part of the PLANS, BID FORM, SPECIFICATIONS, CONTRACT AND BOND for the KANAKALOLOA CEMETERY IMPROVEMENTS, HOOLEHUA, MOLOKAI, HAWAII, and it shall amend the said contract documents as detailed within this Addendum document.

APPROVED:



Norman Sakamoto, LDD Acting Administrator
Department of Hawaiian Home Lands

Date: March 22, 2017

Please detach, execute, and return immediately, the receipt below, to the Department of Hawaiian Home Lands, Hale Kalaniana'ole, 91-5420 Kapolei Parkway, Kapolei, Hawaii or transmit facsimile to (808) 620-9299.

Receipt of Addendum No. 2 for the KANAKALOLOA CEMETERY IMPROVEMENTS, HOOLEHUA, MOLOKAI, HAWAII, is hereby acknowledged.

Signed _____ Title _____

Firm _____ Date _____

ADDENDUM NO. 2
MARCH 22, 2017

TO

PLANS, BID FORM, SPECIFICATIONS, CONTRACT AND BOND

FOR

KANAKALOLOA CEMETERY IMPROVEMENTS

HOOLEHUA, MOLOKAI, HAWAII

IFB-17-HHL-012

ITEM NO. 1 CLARIFICATION ON THE PROPOSED STONEWALL HEIGHT

Question: What is the height on the proposed stonewall? Will the wall be level? Or will the contractor follow the existing ground plans which says 3'6" Typ from existing ground?

Answer: Rock wall should be 3'-6" typical from existing ground, and should follow the existing ground, per sheet C403. The dimension on the elevation on Sheet C402 calls the wall out at 4'-0" high, but the correct height should be 3'-6".

ITEM NO. 2 REVISED BID OPEN DATE

To accommodate **ADDENDUM NO 2 (March 22, 2017)** the bid open date has been changed from 2:00 pm, March 29, 2017 to 2:00 pm, March 30, 2017. The location for bid submittal stated in the IFB remains the same.