

Department of Hawaiian Home Lands 2025 Consumer Confidence Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead

The system inventory includes lead service lines.

To obtain a copy of the most recent lead sampling data or service line inventory documents, please contact Alicia Teves at (808) 774-8722. The Molokai District Office hours are, Monday - Friday, from 7:45am to 4:30pm, excluding holidays.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. HOOLEHUA is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact HOOLEHUA (Public Watersystem Id: HI0000230) by calling 808-774-8720 or emailing david.k.bush@hawaii.gov. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Violations & Exceedances

NONE

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	2.16	1	2.16	2025	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	30.5	14.8	30.5	2025	No	By-product of drinking water disinfection
Inorganic Contaminants								
Antimony (ppb)	6	6	ND	NA	NA	2025	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	00	10	ND	NA	NA	2025	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	NA	NA	NA	2025	No	
Beryllium (ppb)	4	4	ND	NA	NA	2025	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	ND	NA	NA	2025	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	ND	NA	NA	2025	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	200	200	0.005	NA	NA	2025	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Fluoride (ppm)	4	4	ND	NA	NA	2025	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	ND	NA	NA	2025	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	0.31	NA	NA	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	NA	NA	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	ND	NA	NA	2025	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Thallium (ppb)	0.5	2	ND	NA	NA	2025	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Radioactive Contaminants								
Radium (combined 226/228) (pCi/L)	00	5	0.487	NA	NA	2025	No	Erosion of natural deposits
Uranium (ug/L)	00	30	1	NA	NA	2025	No	Erosion of natural deposits
Synthetic organic contaminants including pesticides and herbicides								
Alachlor (ppb)	00	2	ND	NA	NA	2025	No	Runoff from herbicide used on row crops
Atrazine (ppb)	3	3	ND	NA	NA	2025	No	Runoff from herbicide used on row crops
Benzo(a)pyrene (ppt)	00	200	0.02	NA	NA	2025	No	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	40	40	ND	NA	NA	2025	No	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	00	2	ND	NA	NA	2025	No	Residue of banned termiticide
Dalapon (ppb)	200	200	ND	NA	NA	2025	No	Runoff from herbicide used on rights of way
Diquat (ppb)	20	20	0.41	NA	NA	2025	No	Runoff from herbicide use
Endothall (ppb)	100	100	5	NA	NA	2025	No	Runoff from herbicide use
Endrin (ppb)	2	2	ND	NA	NA	2025	No	Residue of banned insecticide
Ethylene dibromide (ppt)	00	50	ND	NA	NA	2025	No	Discharge from petroleum refineries
Glyphosate (ppb)	700	700	ND	NA	NA	2025	No	Runoff from herbicide use
Heptachlor (ppt)	00	400	ND	NA	NA	2025	No	Residue of banned pesticide
Heptachlor epoxide (ppt)	00	200	ND	NA	NA	2025	No	Breakdown of heptachlor
Hexachlorobenzene (ppb)	00	1	0.049	NA	NA	2025	No	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene (ppb)	50	50	ND	NA	NA	2025	No	Discharge from chemical factories
Lindane (ppt)	200	200	ND	NA	NA	2025	No	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	40	40	ND	NA	NA	2025	No	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl [Vydate] (ppb)	200	200	ND	NA	NA	2025	No	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
Pentachlorophenol (ppb)	00	1	ND	NA	NA	2025	No	Discharge from wood preserving factories
Picloram (ppb)	500	500	ND	NA	NA	2025	No	Herbicide runoff
Simazine (ppb)	4	4	ND	NA	NA	2025	No	Herbicide runoff
Toxaphene (ppb)	00	3	ND	NA	NA	2025	No	Runoff/leaching from insecticide used on cotton and cattle

Contaminants	MCLG	AL	Your Water	Range		# Samples Exceeding AL	Sample Date	Exceeds AL	Typical Source
				Low	High				
Inorganic Contaminants									
Copper - action level at consumer taps (ppm)	1.3	1.3	ND	00	00	0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	00	10	ND	NA	00	0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits
For lead and copper: the 90 th percentile concentration of the most recent round(s) of sampling, the number of sampling sites exceeding the action level, and the range of tap sampling results are shown.									
Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source	
				Low	High				
Volatile Organic Contaminants									
1,1,1-Trichloroethane (ppb)	200	200	ND	NA	NA	2025	No	Discharge from metal degreasing sites and other factories	
1,1,2-Trichloroethane (ppb)	3	5	ND	NA	NA	2025	No	Discharge from industrial chemical factories	
1,1-Dichloroethylene (ppb)	7	7	ND	NA	NA	2025	No	Discharge from industrial chemical factories	
1,2,4-Trichlorobenzene (ppb)	70	70	ND	NA	NA	2025	No	Discharge from textile-finishing factories	
1,2-Dichloroethane (ppb)	00	5	ND	NA	NA	2025	No	Discharge from industrial chemical factories	
1,2-Dichloropropane (ppb)	00	5	ND	NA	NA	2025	No	Discharge from industrial chemical factories	
Benzene (ppb)	00	5	ND	NA	NA	2025	No	Discharge from factories; Leaching from gas storage tanks and landfills	
Carbon Tetrachloride (ppb)	00	5	ND	NA	NA	2025	No	Discharge from chemical plants and other industrial activities	
Chlorobenzene (monochlorobenzene) (ppb)	100	100	ND	NA	NA	2025	No	Discharge from chemical and agricultural chemical factories	
Dichloromethane (ppb)	00	5	ND	NA	NA	2025	No	Discharge from pharmaceutical and chemical factories	
Ethylbenzene (ppb)	700	700	ND	NA	NA	2025	No	Discharge from petroleum refineries	
Styrene (ppb)	100	100	ND	NA	NA	2025	No	Discharge from rubber and plastic factories; Leaching from landfills	
Tetrachloroethylene (ppb)	00	5	ND	NA	NA	2025	No	Discharge from factories and dry cleaners	
Toluene (ppm)	1	1	ND	NA	NA	2025	No	Discharge from petroleum factories	
Vinyl Chloride (ppb)	00	2	ND	NA	NA	2025	No	Leaching from PVC piping; Discharge from plastics factories	
Xylenes (ppm)	10	10	ND	NA	NA	2025	No	Discharge from petroleum factories; Discharge from chemical factories	

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
ppt	ppt: parts per trillion, or nanograms per liter
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
90th Percentile	Compliance with the lead and copper action levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected.

For more information please contact:

Contact Name: Bush, David
DEPARTMENT OF HAWAIIAN HOME LANDS,

P.O. BOX 2009
KAUNAKAKAI, HI 96748
Phone: 808-774-8720